

CERTIFICATE

N.9Y56473

Expiry date:09/02/2022

Holder of Certificate:



Classification: IAQ -(Indoor air quality)

particle and microbiological contamination educational areas

MICROBIOLOGICAL/PHYSICAL TESTS

Parameters: CBT(36°C,22°C) Staphilococcus spp
CMT(36°C,22°C) Psudomonas spp
Legionellaceae Enterobacteriaceae
Bacilli GRAM- Aspergillus spp
Aerodisperse particulate

Tested acc.to: ISO14644-1:2015 UNI EN 13098:2002
ISO21501-4 ISPEL 2009

Limite Value: ≤ISO CLASS 5 ≤3520/m³
UFC/m³ <35UFC/m³
Absence of airborne pathogens

Equipment: Aerosol Particle Counter Lasair III
calibration term:09/08/2022
Microbial Air Sampler MAS100NT
calibration term:09/12/2022

Final evaluation:

In accordance to the tests performed, the educational areas of Complesso Scolastico Seraficum meets the compliance requirements established by the quality assurance program and by national and international guidelines on the prevention and control of the airborne infections..The concentration of the particles calculated is in accordance with the UNI EN ISO standard and the airborne microbial loads in line with the expected reference values.

Testing Specialist:
Dr Fabrizio Conti

Rome, 09/02/2021

